

CERTIFICATE OF ANALYSIS

Work Order	: CA2200438	Page	: 1 of 2		
Client	Environmental and Analytical Laboratories	Laboratory	: ALS Water Resources Group		
Contact	: Mr David Wade	Contact	Client Services		
Address	Charles Sturt University Locked Bag 588	Address	: 16B Lithgow Street Fyshwick ACT Australia 2609		
Telephone	Wagga Wagga NSW 2678 : 02 6933 2849	Telephone	: +61 2 6202 5404		
Project	: Microbiological Samples	Date Samples Received	: 21-Jan-2022 10:10		
Order number	: P0185942	Date Analysis Commenced	: 21-Jan-2022		
C-O-C number	:	Issue Date	: 25-Jan-2022 09:01		
Sampler	:		Iac-MRA NAT	A	
Site	:				
Quote number	: Micro Samples		Accreditation N	- 002	
No. of samples received	: 1		Accreditation N Accredited for compliance		
No. of samples analysed	: 1		ISO/IEC 17025 - Te	sting	

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Prasanna Ganta	Teamleader Micro/Bio	Microbiology / Biology, Fyshwick, ACT



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing

purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

^ = This result is computed from individual analyte detections at or above the level of reporting

ø = ALS is not NATA accredited for these tests.

 \sim = Indicates an estimated value.

• For samples collected by ALS WRG, sampling was carried out in accordance with Procedure EN67

Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	Pool water 22Jan-0158						
Sampling date / time			18-Jan-2022 07:00							
Compound	CAS Number	LOR	Unit	CA2200438-001						
				Result						
MW002CA: Heterotrophic Plate Count 20°C - 2 Day										
Heterotrophic Plate Count (20°C)		1	CFU/mL	<1						
MW004CA: Total Coliforms and E. coli by DST										
Total Coliforms (Colilert)		1	MPN/100 mL	<1						
E.coli (Colilert)		1	MPN/100 mL	<1						
MW010CA: Pseudomonas aeruginosa by MF										
Pseudomonas aeruginosa (Presumptive)		1	CFU/100mL	<1						
Pseudomonas aeruginosa (Confirmed)		1	CFU/100mL	<1						