

CERTIFICATE OF ANALYSIS

Work Order	÷ CA2208194	Page	: 1 of 2		
Client	Environmental and Analytical Laboratories	Laboratory	: ALS Water Resources Group		
Contact	: Mr David Wade	Contact	Client Services		
Address	Charles Sturt University Locked Bag 588	Address	: 16B Lithgow Street Fyshwick ACT Australia 2609		
	Wagga Wagga NSW 2678				
Telephone	: 02 6933 2849	Telephone	: +61 2 6202 5404		
Project	: Microbiological Samples	Date Samples Received	: 01-Dec-2022 11:00		
Order number	: PO197464	Date Analysis Commenced	: 01-Dec-2022		
C-O-C number	:	Issue Date	: 06-Dec-2022 12:48		
Sampler	:		Hac-MRA NAIA		
Site	: Pool Water				
Quote number	: Micro Samples				
No. of samples received	:1		Accreditation No. 992 Accredited for compliance with		
No. of samples analysed	:1		ISO/IEC 17025 - Testing		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Prasanna Ganta	Teamleader Micro/Bio	Microbiology / Biology, Fyshwick, ACT



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing

purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key: CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.

LOR = Limit of reporting

^ = This result is computed from individual analyte detections at or above the level of reporting

ø = ALS is not NATA accredited for these tests.

 \sim = Indicates an estimated value.

• For samples collected by ALS WRG, sampling was carried out in accordance with Procedure EN67

Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	Pool Water 22Nov-0244									
Sampling date / time				29-Nov-2022 06:30									
Compound	CAS Number	LOR	Unit	CA2208194-001									
				Result									
MW002CA: Heterotrophic Plate Count 20°C - 2 Day													
Heterotrophic Plate Count (20°C)		1	CFU/mL	<1									
MW004CA: Total Coliforms and E. coli by DST													
Total Coliforms (Colilert)		1	MPN/100 mL	<1									
E.coli (Colilert)		1	MPN/100 mL	<1									
MW010CA: Pseudomonas aeruginosa by MF													
Pseudomonas aeruginosa (Presumptive)		1	CFU/100mL	<1									
Pseudomonas aeruginosa (Confirmed)		1	CFU/100mL	<1									