Program:	Drinking Water Monitoring Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	Gundagai GU01	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-01-2026 - 21-07-2026
Source:	All		
Sample Site:	All		

Sample Count: 31

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2260	1.2000	0.1004	1.14	1.4	5	0	1.4	1.14	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1020	1.0900	0.0769	1.02	1.2	5	0	1.2	1.02	100.00
	Fluoride Ratio	0.8 - 1.2		0.9020	0.8700	0.0879	0.83	1.05	5	0	1.05	0.83	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	26	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6235	0.6000	0.2572	0.22	1.21	26	0	1.1	0.22	100.00
	pH	6.5 - 8.5		7.7635	7.7150	0.4050	7.2	8.78	26	2	8.64	7.32	92.31
	Temperature	30.0000	C	17.7462	18.0000	4.1001	9.6	24	13	0	24	9.6	100.00

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology	Total Chlorine	5.0000	mg/L	0.7012	0.6400	0.3062	0.12	1.4	26	0	1.29	0.24	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0385	0.0000	0.1961	0	1	26	1	0	0	96.15
	Turbidity	5.0000	NTU	0.3158	0.3050	0.0957	0.17	0.58	26	0	0.48	0.18	100.00